



SANITARY CERTIFICATE

THE TAMILNADU EDUCATIONAL RULES CHAPTER—III


Rule 24 & Appendix--3

I hereby declare that I have caused to be inspected the Building and premises of Christ the King School, Christurajapuram, Palugal, Post. Vilavancode Taluk, Kanyakumari District. On 23-08-2022 and Certify that the accommodation provided for each of the several classes is sufficient for the maximum number of pupils taught there in and the rooms properly ventilated and lighted. The building maintained with substantial repairs, and is neat and clean that the latrine arrangements are adequate and satisfactory, that in all other necessary aspects the Sanitation is Satisfaction.

The Certificate valid from 23-08-2022 to 31-05-2023

Certificate is issued with the following conditions:

1. Establishing hand wash facilities at the entrance.
2. All the employees should wear face mask.
3. Maintaining social distancing in all places.
4. Practicing cough etiquette properly.
5. Floors and frequently touched surfaces should be disinfected as per the infection prevention control guidelines.
6. Environment and campus should be kept neat and clean and should be free from Dengue Aedes Larva.
7. Provide safe and protected drinking water.
8. First aid box should be maintained with drugs properly.
9. Tobacco prohibition board should be displayed as per COTPA 2003


BLOCK HEALTH SUPERVISOR
Govt. Primary Health Centre
Eaicode
Kanyakumari District


Ref:L.Dis.No:8972/A4/2022

Office of the Deputy Director of Health Services, Nagercoil

Dated:

Countersigned on the basis of the BHS inspection finding




Deputy Director of Health Services

Nagercoil

20/9/22



TAMIL NADU WATER SUPPLY & DRAINAGE BOARD
District Level Water Testing Laboratory,
TWAD Board, 46/50 Vellalar Colony, Ramavarmapuram, Nagercoil 629001.

TEST REPORT

Ph.04652-238315

From
Er.B.Hari Govind,B.E
Assistant Executive Engineer,
TWAD BOARD,
Maintenance Sub-Division ,
Nagercoil-1 .

To
Correspondent,
Christ The King CBSE School,
Jack Campus,
Kannumamoodu.

Lr.No.F.Drinking/ Lab No.40317-40318/AEE(i.c)/Lab /NGL/19-20/Dated 11.03.2020.

Sir,

Sub : Examination of water sample - Report furnished - Reg.

Ref : 1) Your Lr.No.Nil/ Dt. 02.03.2020

2) Your D.D No.088865/Dt. 29.02.2020 for Rs.1652/-

3) Our Invoice No.8608/Dt. 02.03.2020 for Rs.1652/-

The result of analysis for the water sample sent under reference is furnished below.

Scheme : Drinking Purpose.

Source : Open Well.

Date of Collection : 02.03.2020

Location: Kannumamoodu.

Date of Receipt : 02.03.2020

Lab No: 40317-40318.

BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION.			40317
1. Appearance	-	-	Clear
2. Colour	Agreeable	Agreeable	Colourless
3. Odour	-	-	None
4. Turbidity NT Units	1	5	0
5. Total dissolved Solids mg/L	500	2000	85
6. Electrical Conductivity Micro mho/cm	-	-	128
II.CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	6.17
8. Ph. Alkalinity as CaCo ₃ mg/L	-	-	-
9. Total Alkalinity. as CaCo ₃ mg/L	200	600	24
10. Total Hardness as CaCo ₃ mg/L	200	600	36
11. Calcium as Ca mg/L	75	200	10
12. Magnesium as Mg mg/L	30	100	2
13. Sodium as Na mg/L	-	-	11
14. Potassium as K mg/L	-	-	1
15. Iron as Fe mg/L	0.3	1.0	0.82
16. Manganese mg/L	0.1	0.3	0.00
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	2.54
18. Nitrite as NO ₂ mg/L	-	-	0.03
19. Nitrate as NO ₃ mg/L	45	45	2
20. Chloride as Cl mg/L	250	1000	18
21. Fluoride as F mg/L	1.0	1.5	0.4
22. Sulphate as SO ₄ mg/L	200	400	9
23. Phosphate as PO ₄ mg/L	-	-	0.05
24. Tidys Test 4 hrs.as O ₂ mg/L	-	-	0.36
BACTERIOLOGICAL EXAMINATION			40318
Fecal coliform per 100 ml.	0	0	0

Report:Lab No.-40317: The water is chemically Not potable.

Report:Lab No.-40318: The Water is Bacteriologically Safe.

For Assistant Executive Engineer, TWAD Board
Maintenance Sub-Division, Nagercoil

K. S. S. S. S.
11/03/20